

PAT Report Passes And Fails For all Sites and Locations

CLIENT DETAILS	
Company Name:	Steve Whale-Whaley Entertainments
Address:	5 Middlebere Drive Wareham Dorset BH20 4SD



DETAIL OF CONTRACTOR RESPONSIBLE FOR TESTING	
Company Name:	ACE Testing Ltd
Address:	103 Underwood Road Reading, Berkshire RG30 3PA NICEIC No: PAT 1022
Telephone:	0118 9623451
Mobile:	
Email:	enquiries@acetesting.co.uk
Cert Number:	
Order Number:	
Signature:	

APPLIANCE DETAILS AND TEST RESULTS

Key P = PASS / F = FAIL / S = SKIP (or test not applicable)										
Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status	
STEVE WHALE - WAREHAM										
224441	LEX LED LIGHT	24/07/20	P	S	P 0.19	P 19.99	P <0.05	S	PASS	
315947	IEC LEAD	24/07/20	P	P	P 0.06	P 19.99	S	S	PASS	
315949	EXT CABLE 4 WAY	24/07/20	P	P	P 0.07	P 19.99	S	S	PASS	
315950	EXT CABLE 6 WAY	24/07/20	P	P	P 0.09	P 19.99	S	S	PASS	
315952	EXT CABLE 6 WAY	24/07/20	P	P	P 0.14	P 19.99	S	S	PASS	
315955	EKHO LED LIGHT	24/07/20	P	S	P 0.05	P 19.99	P <0.05	S	PASS	
327821	SOUND DESK 14 WAY	24/07/20	P	S	P 0.07	P 19.99	P <0.05	S	PASS	
327822	IEC LEAD	24/07/20	P	P	P 0.18	P 19.99	S	S	PASS	
327823	IEC LEAD	24/07/20	P	P	P 0.08	P 19.99	S	S	PASS	
327828	EXT CABLE 6 WAY	24/07/20	P	P	P 0.11	P 19.99	S	S	PASS	
327829	EXT CABLE 4 WAY	24/07/20	P	P	P 0.13	P 19.99	S	S	PASS	
327831	SMOKE MACHINE	24/07/20	P	S	P 0.15	P 19.99	P 0.44	S	PASS	
327833	MOVING HEAD LIGHTS	24/07/20	P	S	P 0.10	P 19.99	P <0.05	S	PASS	
327834	MOVING HEAD LIGHTS	24/07/20	P	S	P 0.09	P 19.99	P <0.05	S	PASS	
327835	IEC EXTENSION LEAD	24/07/20	P	P	P 0.09	P 19.99	S	S	PASS	
327836	IEC EXTENSION LEAD	24/07/20	P	P	P 0.25	P 19.99	S	S	PASS	
327837	IEC LEAD	24/07/20	P	P	P 0.14	P 19.99	S	S	PASS	
327840	IEC LEAD	24/07/20	P	P	P 0.04	P 19.99	S	S	PASS	
327842	MICROPAR BAR LIGHTS	24/07/20	P	S	P 0.19	P 19.99	P <0.05	S	PASS	
327843	MICROPAR BAR LIGHTS	24/07/20	P	S	P 0.03	P 19.99	P <0.05	S	PASS	
327844	IEC LEAD	24/07/20	P	P	P 0.21	P 19.99	S	S	PASS	
327845	IEC LEAD	24/07/20	P	P	P 0.20	P 19.99	S	S	PASS	
327846	IEC LEAD	24/07/20	P	P	P 0.06	P 19.99	S	S	PASS	

APPLIANCE DETAILS AND TEST RESULTS

Key P = PASS / F = FAIL / S = SKIP (or test not applicable)										
Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status	
327850	IEC LEAD	24/07/20	P	P	P 0.14	P 19.99	S	S	PASS	
327851	IEC LEAD	24/07/20	P	P	P 0.21	P 19.99	S	S	PASS	
350739	EXT CABLE 4 WAY	24/07/20	S	P	P 0.14	P 19.99	S	S	PASS	
350740	RADIO MIKE PSU	24/07/20	P	S	S	P 19.99	P <0.05	S	PASS	
350741	IEC LEAD	24/07/20	P	P	P 0.15	P 19.99	S	S	PASS	
350743	IEC LEAD	24/07/20	P	P	P 0.07	P 19.99	S	S	PASS	
350744	IEC LEAD	24/07/20	P	P	P 0.09	P 19.99	S	S	PASS	
350746	ART 712A SPEAKERS	24/07/20	P	S	P 0.01	P 19.99	P <0.05	S	PASS	
350747	IEC LEAD	24/07/20	P	P	P 0.06	P 19.99	S	S	PASS	
350748	ART 712A SPEAKERS	24/07/20	P	S	P 0.01	P 19.99	P <0.05	S	PASS	
350750	SPEAKERS AMPLIFIER	24/07/20	P	S	P 0.06	P 19.99	P <0.05	S	PASS	
350751	LOVE LETTERS PSU	24/07/20	P	S	S	P 19.99	P <0.05	S	PASS	
350752	LOVE LETTERS PSU	24/07/20	P	S	S	P 19.99	P <0.05	S	PASS	
350753	LOVE LETTERS PSU	24/07/20	P	S	S	P 19.99	P <0.05	S	PASS	
350754	LOVE LETTERS PSU	24/07/20	P	S	S	P 19.99	P <0.05	S	PASS	
350755	BALL LED LIGHT	24/07/20	P	S	P 0.05	P 19.99	P <0.05	S	PASS	
350757	LED PAR 64 LIGHT	24/07/20	P	S	S	P 19.99	P <0.05	S	PASS	
350758	LED PAR 64 LIGHT	24/07/20	P	S	S	P 19.99	P <0.05	S	PASS	
350759	LED PAR 64 LIGHT	24/07/20	P	S	S	P 19.99	P <0.05	S	PASS	
350761	LED PAR 64 LIGHT	24/07/20	P	S	S	P 19.99	P <0.05	S	PASS	
350762	IEC LEAD	24/07/20	P	P	P 0.25	P 19.99	S	S	PASS	
350763	IEC LEAD	24/07/20	P	P	P 0.07	P 19.99	S	S	PASS	
350764	FLAME LIGHT BOX	24/07/20	P	S	P 0.09	P 19.99	P 0.31	S	PASS	
350765	FLAME LIGHT BOX	24/07/20	P	S	P 0.04	P 19.99	P 0.45	S	PASS	
385233	IEC LEAD	24/07/20	P	P	P 0.05	P 19.99	S	S	PASS	
385234	DIGITAL MIXER	24/07/20	P	S	P 0.02	P 19.99	P <0.05	S	PASS	
385235	INEAR MONITOR UNIT PSU	24/07/20	P	S	S	P 19.99	P <0.05	S	PASS	
385236	SOUND DESK 10 WAY	24/07/20	P	S	P 0.04	P 19.99	P <0.05	S	PASS	
385237	LED PAR 64 LIGHT	24/07/20	P	S	S	P 19.99	P <0.05	S	PASS	
385238	XMAS LIGHTS	24/07/20	P	S	S	P 19.99	P <0.05	S	PASS	
385239	EQUINOX LED LIGHT BAR	24/07/20	P	S	P 0.03	P 19.99	P <0.05	S	PASS	
385242	IEC LEAD	24/07/20	P	P	P 0.06	P 19.99	S	S	PASS	
385243	IEC LEAD	24/07/20	P	P	P 0.08	P 19.99	S	S	PASS	

 Total Appliances > **56**
Total Appliances For Report: 56